



Menesine ataskaita: 03/2026

	UAB Gren Klaipeda			sugenerouta: 3/9/2026		
	Klaip L1 H ₂ O Day Conc	Klaip L1 CO ₂ Day Conc	Klaip L1 CO Day Conc	Klaip L1 SO ₂ Day Conc	Klaip L1 NH ₃ Day Conc	Klaip L1 HCl Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/03/	12.92	7.67	4.15	5.09	1.20	0.11
02/03/	11.16	7.78	4.16	4.23	1.16	0.11
03/03/	12.01	7.74	3.83	3.28	1.17	0.11
04/03/	12.38	7.72	6.42	4.96	1.18	0.11
05/03/	11.87	7.77	4.23	2.89	1.18	0.11
06/03/	11.27	7.70	4.49	3.52	1.16	0.11
07/03/	13.15	7.76	4.61	3.30	1.20	0.11
08/03/	14.21	7.70	2.85	2.49	1.26	0.11
min	11.16	7.67	2.85	2.49	1.16	0.11
max	14.21	7.78	6.42	5.09	1.26	0.11
MMV	12.37	7.73	4.34	3.72	1.19	0.11
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Menesine ataskaita: 03/2026

	UAB Gren Klaipeda					
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srutas Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/03/	0.08	0.00	132.42	0.41	0.04	231035.98
02/03/	0.08	0.00	132.14	0.36	0.04	227464.27
03/03/	0.08	0.00	133.68	0.31	0.03	228446.41
04/03/	0.08	0.05	131.42	0.35	0.04	230699.94
05/03/	0.08	0.00	132.58	0.37	0.03	228392.23
06/03/	0.08	0.00	132.50	0.37	0.04	227616.64
07/03/	0.08	0.00	133.04	0.38	0.04	229256.49
08/03/	0.08	0.00	133.24	0.40	0.04	230375.64
min	0.08	0.00	131.42	0.31	0.03	227464.27
max	0.08	0.05	133.68	0.41	0.04	231035.98
MMV	0.08	0.01	132.63	0.37	0.04	229160.95
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Mensina ataskaita: 03/2026

	UAB Gren Klaipeda			sugenerouta: 3/9/2026		
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
Diena	°C	mbar	Vol%	mbar	°C	mg/Nm ³
01/03/	47.44	1037.68	5.76	1016.06	1117.23	4.61
02/03/	45.24	1041.96	5.87	1020.06	1107.49	4.62
03/03/	46.58	1043.77	5.82	1022.05	1107.48	4.26
04/03/	47.12	1040.33	5.78	1018.42	1118.54	7.01
05/03/	46.34	1043.66	5.87	1020.83	1098.40	4.70
06/03/	45.39	1045.98	5.94	1024.01	1119.64	5.00
07/03/	48.21	1048.58	5.80	1025.76	1119.78	5.12
08/03/	49.51	1052.56	5.69	1029.13	1158.81	3.16
min	45.24	1037.68	5.69	1016.06	1098.40	3.16
max	49.51	1052.56	5.94	1029.13	1158.81	7.01
MMV	46.98	1044.31	5.82	1022.04	1118.42	4.81
<p>- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement</p>						



Menesine ataskaita: 03/2026

	UAB Gren Klaipeda						sugenerouta: 3/9/2026
	Klaip L1 SO ₂ 97% Day Conc	Klaip L1 HCl 97% Day Conc	Klaip L1 HF 97% Day Conc	Klaip L1 NO _x 97% Day Conc	Klaip L1 TOC 97% Day Conc	Klaip L1 Dulkes 97% Day Conc	
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	
01/03/	D 5.52	0.16	0.11	144.12	0.50	0.05	
02/03/	4.69	0.17	0.11	146.73	0.46	0.06	
03/03/	3.61	0.16	0.11	147.02	0.39	0.03	
04/03/	D 5.42	0.16	0.11	143.94	0.45	0.05	
05/03/	3.18	0.17	0.11	146.04	0.46	0.04	
06/03/	3.90	0.17	0.11	146.95	0.47	0.06	
07/03/	3.58	0.16	0.11	144.41	0.47	0.05	
08/03/	2.68	0.16	0.11	142.85	0.49	0.05	
min	2.68	0.16	0.11	142.85	0.39	0.03	
max	5.52	0.17	0.11	147.02	0.50	0.06	
MMV	4.08	0.16	0.11	145.26	0.46	0.05	
<p>- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement</p>							