



Menesine ataskaita: 05/2026

	UAB Gren Klaipeda			sugenerouta: 6/1/2026		
	Klaip L1 H ₂ O Day Conc	Klaip L1 CO ₂ Day Conc	Klaip L1 CO Day Conc	Klaip L1 SO ₂ Day Conc	Klaip L1 NH ₃ Day Conc	Klaip L1 HCl Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/05/	16.29	7.80	2.16	3.30	1.26	0.12
02/05/	17.06	7.81	3.56	3.15	1.22	0.12
03/05/	18.28	7.67	2.96	3.30	1.22	0.12
04/05/	19.65	7.71	3.37	4.54	1.25	0.12
05/05/	16.41	7.82	1.78	3.11	1.25	0.12
06/05/	16.23	7.85	1.35	3.82	1.23	0.12
07/05/	16.03	7.86	3.26	3.35	1.23	0.12
08/05/	14.47	7.85	2.84	3.01	1.24	0.12
09/05/	16.75	7.74	1.31	3.23	1.24	0.12
10/05/	18.49	7.72	3.46	2.93	1.28	0.12
11/05/	16.92	7.70	1.90	3.22	1.28	0.12
12/05/	14.91	7.70	2.04	3.41	1.23	0.12
13/05/	14.92	7.71	1.31	3.42	1.27	0.12
14/05/	16.17	7.60	1.83	3.42	1.29	0.12
15/05/	14.41	7.53	2.37	3.27	1.21	0.11
16/05/	17.80	7.47	1.61	3.61	1.21	0.12
17/05/	16.57	7.47	1.93	4.96	1.21	0.12
18/05/	15.73	7.51	1.19	3.27	1.20	0.12
19/05/	15.24	7.49	1.70	3.29	1.19	0.11
20/05/	15.14	7.60	3.54	3.08	1.18	0.11
21/05/	14.89	7.65	2.40	2.93	1.19	0.11
22/05/	16.79	7.58	2.45	3.33	1.20	0.12
23/05/	17.10	7.49	2.58	2.86	1.20	0.12
24/05/	16.88	7.46	2.19	2.93	1.19	0.12
25/05/	16.81	7.51	2.39	3.09	1.19	0.12
26/05/	15.06	7.53	1.17	3.15	1.20	0.11
27/05/	15.56	7.57	1.94	3.71	1.19	0.11
28/05/	15.48	7.50	1.81	3.54	1.18	0.11
29/05/	15.22	7.58	2.32	3.46	1.19	0.11
30/05/	16.07	7.50	2.22	4.03	1.19	0.12
31/05/	16.20	7.52	2.72	4.54	1.19	0.12
min	14.41	7.46	1.17	2.86	1.18	0.11
max	19.65	7.86	3.56	4.96	1.29	0.12
MMV	16.24	7.63	2.25	3.43	1.22	0.12
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Menesine ataskaita: 05/2026

	UAB Gren Klaipeda				sugenerouta: 6/1/2026	
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srutas Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/05/	0.08	0.00	133.82	0.53	0.02	227253.50
02/05/	0.08	0.00	133.69	0.60	0.03	228592.98
03/05/	0.08	0.00	133.90	0.57	0.03	228282.94
04/05/	0.08	0.01	133.77	0.60	0.05	228145.84
05/05/	0.08	0.00	133.45	0.53	0.04	218638.17
06/05/	0.08	0.00	133.13	0.54	0.06	219726.37
07/05/	0.08	0.00	132.60	0.41	0.04	219204.21
08/05/	0.08	0.00	132.13	0.42	0.02	206222.78
09/05/	0.08	0.00	133.39	0.69	0.04	222824.04
10/05/	0.08	0.00	134.18	0.69	0.02	225168.57
11/05/	0.08	0.00	133.30	0.49	0.05	223049.42
12/05/	0.08	0.00	132.78	0.41	0.04	218982.64
13/05/	0.08	0.00	133.16	0.35	0.02	218834.86
14/05/	0.08	0.00	133.30	0.43	0.03	227856.72
15/05/	0.07	0.00	133.36	0.32	0.02	229847.26
16/05/	0.07	0.00	133.84	0.40	0.06	235185.72
17/05/	0.08	0.00	133.81	0.38	0.04	233150.69
18/05/	0.07	0.00	133.59	0.42	0.04	230665.89
19/05/	0.07	0.00	133.37	0.41	0.03	229496.99
20/05/	0.07	0.00	133.26	0.40	0.02	230117.62
21/05/	0.07	0.00	133.41	0.43	0.04	229046.33
22/05/	0.07	0.00	133.46	0.43	0.02	233225.87
23/05/	0.08	0.00	133.68	0.57	0.02	233868.73
24/05/	0.07	0.00	133.16	0.56	0.04	228326.17
25/05/	0.07	0.00	133.10	0.55	0.04	228086.49
26/05/	0.07	0.00	133.58	0.48	0.03	229736.16
27/05/	0.07	0.00	133.24	0.46	0.03	231960.77
28/05/	0.07	0.00	133.38	0.50	0.03	231091.99
29/05/	0.08	0.00	133.54	0.37	0.02	230457.08
30/05/	0.08	0.00	133.48	0.43	0.03	232263.25
31/05/	0.08	0.01	133.66	0.52	0.05	232448.15
min	0.07	0.00	132.13	0.32	0.02	206222.78
max	0.08	0.01	134.18	0.69	0.06	235185.72
MMV	0.08	0.00	133.40	0.48	0.03	227153.49
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Mensina ataskaita: 05/2026

	UAB Gren Klaipeda			sugenerouta: 6/1/2026		
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
Diena	°C	mbar	Vol%	mbar	°C	mg/Nm ³
01/05/	52.68	1047.23	5.56	1022.89	1125.20	2.40
02/05/	53.66	1042.26	5.46	1017.76	1121.48	3.96
03/05/	55.07	1034.71	5.40	1010.36	1081.62	3.26
04/05/	56.61	1028.99	5.47	1007.18	1108.92	3.76
05/05/	52.75	1029.80	5.85	1008.30	1071.95	1.98
06/05/	52.53	1029.17	5.84	1008.41	1095.30	1.50
07/05/	52.28	1032.00	5.69	1010.05	1090.94	3.62
08/05/	50.34	1041.08	6.19	1017.97	1065.09	3.15
09/05/	53.31	1042.16	5.99	1018.64	1093.17	1.46
10/05/	55.38	1037.34	5.91	1014.11	1065.90	3.85
11/05/	53.29	1027.35	6.04	1003.10	1071.92	2.12
12/05/	50.69	1017.34	6.15	997.15	1067.20	2.28
13/05/	50.75	1018.05	6.15	996.74	1060.12	1.46
14/05/	52.32	1021.64	5.68	998.22	1061.62	2.04
15/05/	50.11	1024.47	5.57	1000.34	1060.14	2.62
16/05/	54.38	1023.00	5.33	1002.30	1082.93	1.79
17/05/	53.04	1034.76	5.44	1013.08	1058.75	2.15
18/05/	52.00	1036.57	5.52	1013.51	1074.95	1.32
19/05/	51.36	1035.42	5.51	1013.34	1071.63	1.90
20/05/	51.27	1042.83	5.49	1019.44	1062.72	3.95
21/05/	50.99	1043.19	5.53	1020.03	1070.01	2.68
22/05/	53.40	1044.73	5.45	1022.59	1028.57	2.71
23/05/	53.85	1047.64	5.42	1024.07	1050.03	2.87
24/05/	53.53	1043.97	5.41	1020.76	1051.96	2.44
25/05/	53.44	1044.93	5.41	1021.83	1042.36	2.66
26/05/	51.14	1037.97	5.53	1015.13	1069.79	1.30
27/05/	51.69	1034.24	5.53	1011.32	1025.65	2.15
28/05/	51.66	1038.15	5.55	1015.52	1056.52	2.01
29/05/	51.33	1039.51	5.53	1016.66	1053.55	2.58
30/05/	52.35	1034.30	5.49	1010.51	1049.01	2.46
31/05/	52.47	1030.47	5.48	1008.00	1080.57	3.03
min	50.11	1017.34	5.33	996.74	1025.65	1.30
max	56.61	1047.64	6.19	1024.07	1125.20	3.96
MMV	52.57	1035.01	5.63	1012.24	1069.99	2.50
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Menesine ataskaita: 05/2026

	UAB Gren Klaipeda			sugenerouta: 6/1/2026		
	Klaip L1 SO ₂ 97% Day Conc	Klaip L1 HCl 97% Day Conc	Klaip L1 HF 97% Day Conc	Klaip L1 NO _x 97% Day Conc	Klaip L1 TOC 97% Day Conc	Klaip L1 Dulkes 97% Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/05/	3.46	0.16	0.11	140.02	0.63	0.03
02/05/	3.26	0.16	0.11	138.59	0.71	0.03
03/05/	3.38	0.16	0.10	136.78	0.67	0.03
04/05/	4.55	0.16	0.10	134.36	0.69	0.06
05/05/	3.25	0.16	0.11	139.43	0.63	0.05
06/05/	3.99	0.17	0.11	139.40	0.64	0.07
07/05/	3.51	0.16	0.11	139.17	0.50	0.05
08/05/	3.22	0.17	0.11	141.23	0.51	0.03
09/05/	3.36	0.17	0.11	138.82	0.82	0.05
10/05/	2.98	0.17	0.11	136.72	0.81	0.03
11/05/	3.34	0.17	0.11	138.43	0.58	0.06
12/05/	3.63	0.17	0.11	141.21	0.50	0.05
13/05/	3.64	0.17	0.11	141.61	0.43	0.03
14/05/	3.58	0.16	0.11	139.67	0.51	0.04
15/05/	3.50	0.16	0.10	142.68	0.40	0.02
16/05/	3.71	0.16	0.10	137.51	0.47	0.06
17/05/	D 5.19	0.16	0.10	139.53	0.45	0.04
18/05/	3.44	0.16	0.10	140.72	0.51	0.05
19/05/	3.48	0.16	0.10	141.31	0.49	0.04
20/05/	3.27	0.16	0.10	141.35	0.49	0.03
21/05/	3.11	0.16	0.10	141.92	0.52	0.04
22/05/	3.46	0.16	0.10	138.82	0.51	0.02
23/05/	2.96	0.16	0.10	138.51	0.68	0.03
24/05/	3.04	0.16	0.10	138.36	0.67	0.04
25/05/	3.21	0.16	0.10	138.41	0.65	0.04
26/05/	3.34	0.16	0.10	141.83	0.58	0.03
27/05/	3.91	0.16	0.10	140.65	0.55	0.04
28/05/	3.73	0.16	0.10	140.92	0.61	0.03
29/05/	3.67	0.16	0.11	141.50	0.45	0.03
30/05/	4.22	0.16	0.11	140.04	0.52	0.03
31/05/	4.76	0.16	0.11	140.00	0.63	0.05
min	2.96	0.16	0.10	134.36	0.40	0.02
max	5.19	0.17	0.11	142.68	0.82	0.07
MMV	3.59	0.16	0.11	139.66	0.57	0.04
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						