



Menesine ataskaita: 06/2026

	UAB Gren Klaipeda			sugenerouta: 6/30/2026		
	Klaip L1 H ₂ O Day Conc	Klaip L1 CO ₂ Day Conc	Klaip L1 CO Day Conc	Klaip L1 SO ₂ Day Conc	Klaip L1 NH ₃ Day Conc	Klaip L1 HCl Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/06/	16.95	7.56	3.43	4.11	1.20	0.12
02/06/	15.49	7.72	2.15	4.06	1.21	0.12
03/06/	14.06	7.68	2.14	3.99	1.19	0.12
04/06/	16.35	7.54	0.80	4.39	1.21	0.12
05/06/	15.46	7.51	0.12	4.25	1.20	0.12
06/06/	16.50	7.51	1.23	3.59	1.20	0.12
07/06/	16.89	7.62	0.59	4.07	1.21	0.12
08/06/	17.82	7.56	1.05	4.01	1.22	0.12
09/06/	15.86	7.56	1.04	3.43	1.20	0.12
10/06/	14.74	7.69	0.21	4.17	1.20	0.12
11/06/	14.68	7.56	3.45	3.57	1.24	0.12
12/06/	15.23	7.58	4.57	3.72	1.22	0.12
13/06/	16.18	7.62	1.52	4.18	1.19	0.12
14/06/	14.98	7.45	22.05	4.57	1.25	0.12
15/06/	X	X	X	X	X	X
16/06/	X	X	X	X	X	X
17/06/	X	X	X	X	X	X
18/06/	X	X	X	X	X	X
19/06/	11.03	8.99	D 398.24	7.40	1.77	0.26
20/06/	19.76	7.70	10.65	2.56	1.58	0.17
21/06/	18.10	8.00	7.13	8.61	1.47	0.16
22/06/	15.70	7.95	7.10	4.15	1.37	0.16
23/06/	15.86	8.04	11.90	3.92	1.39	0.17
24/06/	17.44	7.92	2.52	1.82	1.41	0.13
25/06/	18.10	7.92	1.24	0.61	1.40	0.12
26/06/	15.93	8.07	1.96	4.68	1.31	0.14
27/06/	17.56	8.12	10.17	2.87	1.35	0.15
28/06/	17.41	7.99	3.71	3.88	1.36	0.13
29/06/	18.97	7.96	1.29	3.29	1.35	0.13
min	11.03	7.45	0.12	0.61	1.19	0.12
max	19.76	8.99	398.24	8.61	1.77	0.26
MMV	16.38	7.75	5.22	3.86	1.29	0.13
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Menesine ataskaita: 06/2026

	UAB Gren Klaipeda				sugenerouta: 6/30/2026	
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srutas Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/06/	0.08	0.00	133.07	0.56	0.02	233330.46
02/06/	0.08	0.00	133.26	0.40	0.03	227768.97
03/06/	0.08	0.00	133.12	0.30	0.03	225730.27
04/06/	0.08	0.00	133.57	0.49	0.03	229536.16
05/06/	0.07	0.00	133.71	0.41	0.04	226492.87
06/06/	0.08	0.00	133.60	0.48	0.01	228108.66
07/06/	0.08	0.00	133.72	0.46	0.04	230195.19
08/06/	0.08	0.00	133.73	0.49	0.03	231598.63
09/06/	0.08	0.00	133.45	0.47	0.03	228093.57
10/06/	0.07	0.00	133.13	0.37	0.03	225371.17
11/06/	0.08	0.00	133.13	0.45	0.14	219617.01
12/06/	0.08	0.00	132.93	0.49	0.01	218486.36
13/06/	0.08	0.00	133.44	0.52	0.05	227016.81
14/06/	0.08	0.54	130.40	0.87	0.04	208053.86
15/06/	X	X	X	X	X	X
16/06/	X	X	X	X	X	X
17/06/	X	X	X	X	X	X
18/06/	X	X	X	X	X	X
19/06/	0.10	7.50	127.58	0.82	0.14	101619.41
20/06/	0.08	0.00	133.03	0.42	0.05	225703.60
21/06/	0.08	0.04	133.77	0.38	0.05	225653.47
22/06/	0.08	0.01	132.44	0.30	0.03	219054.23
23/06/	0.08	0.00	133.48	0.27	0.05	216922.43
24/06/	0.08	0.00	133.68	0.29	0.02	222775.05
25/06/	0.08	0.00	134.63	0.38	0.03	223709.85
26/06/	0.07	0.01	131.79	0.37	0.04	220301.29
27/06/	0.08	0.00	127.20	0.31	0.05	222753.97
28/06/	0.07	0.00	130.94	0.36	0.07	204163.93
29/06/	0.08	0.00	133.58	0.36	0.08	225151.00
min	0.07	0.00	127.20	0.27	0.01	101619.41
max	0.10	7.50	134.63	0.87	0.14	233330.46
MMV	0.08	0.04	132.86	0.42	0.04	219514.89
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Mensina ataskaita: 06/2026

	UAB Gren Klaipeda			sugenerouta: 6/30/2026		
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
Diena	°C	mbar	Vol%	mbar	°C	mg/Nm ³
01/06/	53.47	1035.07	5.52	1010.71	1069.82	3.83
02/06/	51.66	1034.76	5.79	1011.32	1120.64	2.39
03/06/	49.75	1033.27	5.88	1009.06	1103.08	2.37
04/06/	52.67	1030.32	5.70	1007.34	1107.13	0.89
05/06/	51.56	1030.38	5.76	1008.01	1147.86	0.13
06/06/	52.94	1036.31	5.67	1013.65	1106.41	1.34
07/06/	53.49	1040.26	5.65	1016.68	1112.14	0.66
08/06/	54.62	1038.21	5.58	1015.45	1118.98	1.17
09/06/	52.12	1034.04	5.73	1010.20	1090.56	1.15
10/06/	50.74	1036.05	5.82	1013.93	1116.37	0.24
11/06/	50.49	1032.71	6.31	1011.59	1095.61	3.91
12/06/	51.38	1038.54	6.05	1014.68	1071.31	5.16
13/06/	52.46	1030.96	5.54	1007.74	1085.29	1.69
14/06/	50.46	1020.11	6.03	998.02	1079.16	9.23
15/06/	X	X	X	X	X	X
16/06/	X	X	X	X	X	X
17/06/	X	X	X	X	X	X
18/06/	X	X	X	X	X	X
19/06/	47.41	1042.61	14.20	1017.39	906.44	D 106.04
20/06/	57.42	1044.90	6.72	1019.27	965.89	11.87
21/06/	55.55	1043.10	5.86	1019.44	1002.17	7.91
22/06/	52.77	1042.99	5.91	1019.88	1004.65	7.95
23/06/	52.96	1041.98	6.06	1018.96	1008.70	13.33
24/06/	54.90	1038.53	5.78	1015.35	1037.59	2.78
25/06/	55.64	1038.08	5.51	1013.55	1052.73	1.37
26/06/	53.03	1040.72	5.51	1016.92	1074.36	2.21
27/06/	55.01	1041.73	5.50	1017.33	1061.99	11.33
28/06/	54.85	1039.48	5.41	1014.53	1050.49	4.14
29/06/	56.60	1037.47	5.28	1014.35	1070.81	1.44
min	47.41	1020.11	5.28	998.02	906.44	0.13
max	57.42	1044.90	14.20	1019.88	1147.86	106.04
MMV	52.97	1036.82	5.92	1013.35	1070.20	4.38
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



Menesine ataskaita: 06/2026

	UAB Gren Klaipeda			sugenerouta: 6/30/2026		
	Klaip L1 SO ₂ 97% Day Conc	Klaip L1 HCl 97% Day Conc	Klaip L1 HF 97% Day Conc	Klaip L1 NO _x 97% Day Conc	Klaip L1 TOC 97% Day Conc	Klaip L1 Dulkes 97% Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/06/	4.26	0.16	0.11	138.13	0.66	0.02
02/06/	4.28	0.16	0.11	140.77	0.49	0.03
03/06/	4.29	0.17	0.11	143.01	0.36	0.04
04/06/	4.59	0.16	0.11	139.66	0.59	0.04
05/06/	4.48	0.16	0.11	141.31	0.49	0.04
06/06/	3.75	0.16	0.11	139.45	0.58	0.02
07/06/	4.22	0.16	0.10	138.92	0.55	0.04
08/06/	4.12	0.16	0.10	137.37	0.58	0.04
09/06/	3.61	0.16	0.11	140.36	0.56	0.04
10/06/	4.45	0.16	0.11	141.87	0.45	0.03
11/06/	3.80	0.17	0.11	141.96	0.55	0.17
12/06/	3.94	0.17	0.11	140.85	0.60	0.01
13/06/	4.38	0.16	0.11	139.80	0.62	0.07
14/06/	4.82	0.17	0.11	137.26	1.08	0.05
15/06/	X	X	X	X	X	X
16/06/	X	X	X	X	X	X
17/06/	X	X	X	X	X	X
18/06/	X	X	X	X	X	X
19/06/	D 7.40	0.37	0.14	134.31	D 13.22	0.17
20/06/	D 2.58	0.23	0.11	133.36	0.48	0.05
21/06/	D 8.90	0.22	0.11	136.93	0.47	0.06
22/06/	4.36	0.23	0.11	139.55	0.36	0.04
23/06/	4.05	0.24	0.11	140.38	0.32	0.06
24/06/	1.86	0.18	0.11	137.96	0.34	0.03
25/06/	0.62	0.17	0.10	137.84	0.44	0.03
26/06/	4.92	0.20	0.10	138.49	0.44	0.05
27/06/	2.97	0.21	0.10	131.05	0.37	0.06
28/06/	4.00	0.18	0.10	135.16	0.43	0.09
29/06/	3.30	0.17	0.10	135.28	0.42	0.09
min	0.62	0.16	0.10	131.05	0.32	0.01
max	8.90	0.37	0.14	143.01	13.22	0.17
MMV	4.03	0.18	0.11	138.61	0.54	0.05
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						