



Menesine ataskaita: 07/2026

	UAB Gren Klaipeda			sugenerouta: 7/31/2026		
	Klaip L1 H ₂ O	Klaip L1 CO ₂	Klaip L1 CO	Klaip L1 SO ₂	Klaip L1 NH ₃	Klaip L1 HCl
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/07/	16.58	7.99	1.79	4.23	1.31	0.13
02/07/	15.89	8.05	4.81	1.46	1.30	0.15
03/07/	16.86	7.94	1.39	1.82	1.35	0.13
04/07/	18.31	7.91	2.89	4.29	1.36	0.13
05/07/	17.55	7.87	3.96	2.62	1.32	0.13
06/07/	18.00	7.88	3.47	2.48	1.33	0.12
07/07/	16.79	7.90	13.17	1.09	1.35	0.14
08/07/	17.42	7.61	4.87	1.40	1.36	0.14
09/07/	18.47	7.72	4.75	0.79	1.37	0.13
10/07/	18.62	7.82	6.20	0.56	1.38	0.14
11/07/	19.68	7.70	2.15	0.77	1.41	0.15
12/07/	19.18	7.73	4.13	0.44	1.37	0.15
13/07/	18.31	7.86	3.29	0.96	1.36	0.18
14/07/	17.54	7.90	3.31	1.73	1.34	0.14
15/07/	17.70	7.81	1.34	0.60	1.34	0.14
16/07/	17.30	7.94	5.55	1.30	1.31	0.13
17/07/	19.58	7.93	3.91	0.66	1.38	0.15
18/07/	20.36	7.85	3.85	0.54	1.40	0.14
19/07/	19.18	7.82	4.88	0.30	1.40	0.13
20/07/	18.39	7.84	4.06	0.61	1.41	0.29
21/07/	17.70	7.89	10.66	0.49	1.37	0.13
22/07/	17.97	7.83	3.87	2.24	1.35	0.12
23/07/	18.65	7.91	7.62	2.63	1.38	0.14
24/07/	18.41	7.88	8.64	0.70	1.44	0.15
25/07/	18.66	7.88	4.34	0.75	1.44	0.15
26/07/	19.56	7.78	6.36	0.33	1.51	0.14
27/07/	19.13	7.80	4.68	1.01	1.53	0.13
28/07/	16.36	8.05	7.98	0.97	1.38	0.13
29/07/	17.58	8.02	4.30	1.15	1.41	0.13
30/07/	16.20	7.99	4.34	2.19	1.37	0.13
min	15.89	7.61	1.34	0.30	1.30	0.12
max	20.36	8.05	13.17	4.29	1.53	0.29
MMV	18.06	7.87	4.89	1.37	1.38	0.14

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 07/2026

	UAB Gren Klaipeda			sugenerouta: 7/31/2026		
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srautas Day Flow
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/07/	0.07	0.01	131.49	0.35	0.04	221846.52
02/07/	0.07	0.00	132.28	0.32	0.03	220055.96
03/07/	0.07	0.00	133.76	0.38	0.02	222380.50
04/07/	0.08	0.02	133.22	0.42	0.02	226137.03
05/07/	0.08	0.01	132.89	0.33	0.02	224191.53
06/07/	0.08	0.02	132.04	0.37	0.03	225104.13
07/07/	0.08	0.01	131.34	0.26	0.03	221271.34
08/07/	0.08	0.00	133.21	0.32	0.14	225192.57
09/07/	0.08	0.00	133.40	0.41	0.06	228675.05
10/07/	0.08	0.00	133.44	0.41	0.05	229237.25
11/07/	0.08	0.00	134.10	0.35	0.04	231455.60
12/07/	0.08	0.00	133.60	0.37	0.04	228052.17
13/07/	0.08	0.00	133.95	0.34	0.07	224531.69
14/07/	0.08	0.00	133.15	0.35	0.05	224790.30
15/07/	0.08	0.00	133.42	0.35	0.04	226879.59
16/07/	0.07	0.00	132.92	0.31	0.06	215617.19
17/07/	0.08	0.01	133.63	0.42	0.07	225699.31
18/07/	0.08	0.00	134.19	0.33	0.02	229367.48
19/07/	0.08	0.00	133.76	0.33	0.01	227151.23
20/07/	0.08	0.00	133.55	0.37	0.05	224302.63
21/07/	0.08	0.00	133.36	0.30	0.02	222259.51
22/07/	0.08	0.00	133.53	0.35	0.02	225590.63
23/07/	0.08	0.00	133.58	0.35	0.02	226431.14
24/07/	0.08	0.01	133.20	0.34	0.03	226006.48
25/07/	0.08	0.01	133.81	0.35	0.03	227144.78
26/07/	0.08	0.00	133.37	0.41	0.03	229714.74
27/07/	0.08	0.00	133.48	0.43	0.04	226218.17
28/07/	0.07	0.01	131.74	0.34	0.01	218573.45
29/07/	0.08	0.00	132.36	0.34	0.01	222695.20
30/07/	0.08	0.00	132.27	0.42	0.05	219121.03
min	0.07	0.00	131.34	0.26	0.01	215617.19
max	0.08	0.02	134.19	0.43	0.14	231455.60
MMV	0.08	0.00	133.13	0.36	0.04	224856.47

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Mensina ataskaita: 07/2026

	UAB Gren Klaipeda				sugenerouta: 7/31/2026	
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
	Diena	°C	mbar	Vol%	mbar	°C
01/07/	53.82	1036.84	5.54	1014.99	1139.34	2.01
02/07/	52.91	1035.20	5.51	1011.28	1085.50	5.34
03/07/	54.03	1028.72	5.57	1006.38	1076.99	1.54
04/07/	55.78	1029.94	5.46	1006.91	1085.08	3.24
05/07/	54.86	1027.38	5.50	1004.52	1060.81	4.42
06/07/	55.39	1026.25	5.48	1003.53	1082.77	3.88
07/07/	53.83	1020.55	5.63	997.54	1040.05	14.72
08/07/	54.45	1014.43	5.94	992.65	1056.40	5.43
09/07/	55.91	1025.57	5.86	1002.38	1055.81	5.30
10/07/	56.22	1033.46	5.89	1009.83	1048.55	6.82
11/07/	57.42	1035.27	5.76	1012.20	1069.68	2.38
12/07/	56.88	1037.39	5.60	1012.94	1029.35	4.59
13/07/	55.94	1039.05	5.44	1015.85	1063.34	3.66
14/07/	55.04	1040.38	5.50	1017.35	1082.23	3.70
15/07/	55.28	1042.97	5.47	1019.05	1089.51	1.49
16/07/	54.78	1042.69	5.46	1018.65	1043.50	6.18
17/07/	57.35	1037.96	5.33	1013.35	1056.45	4.34
18/07/	58.03	1026.73	5.27	1004.14	1050.91	4.30
19/07/	56.84	1031.89	5.43	1008.87	1020.32	5.44
20/07/	59.31	1031.04	5.47	1008.60	1029.25	4.52
21/07/	55.10	1029.31	5.72	1007.07	990.63	11.74
22/07/	55.50	1032.87	5.51	1009.36	1037.90	4.31
23/07/	56.19	1029.82	5.42	1006.55	1042.32	8.50
24/07/	55.98	1033.46	5.54	1009.95	1018.74	9.62
25/07/	56.24	1030.77	5.46	1007.08	1034.04	4.84
26/07/	57.14	1025.10	5.33	1001.15	1015.98	7.05
27/07/	56.65	1021.48	5.42	998.91	1021.07	5.23
28/07/	53.49	1031.96	5.59	1009.52	1044.75	8.91
29/07/	55.07	1040.78	5.55	1016.96	1059.03	4.79
30/07/	53.43	1042.48	5.80	1017.31	1086.92	4.85
min	52.91	1014.43	5.27	992.65	990.63	1.49
max	59.31	1042.97	5.94	1019.05	1139.34	14.72
MMV	55.63	1032.06	5.55	1008.83	1053.91	5.44
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



	UAB Gren Klaipeda			sugenerouta: 7/31/2026		
	Klaip L1 SO ₂ 97% Day Conc	Klaip L1 HCl 97% Day Conc	Klaip L1 HF 97% Day Conc	Klaip L1 NO _x 97% Day Conc	Klaip L1 TOC 97% Day Conc	Klaip L1 Dulkes 97% Day Conc
	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
Diena						
01/07/	4.41	0.18	0.10	137.10	0.41	0.05
02/07/	1.52	0.20	0.10	139.07	0.38	0.04
03/07/	1.89	0.18	0.10	139.01	0.45	0.02
04/07/	4.39	0.17	0.10	136.04	0.49	0.02
05/07/	2.69	0.18	0.10	136.96	0.39	0.03
06/07/	2.55	0.17	0.10	135.32	0.43	0.04
07/07/	1.13	0.20	0.10	136.59	0.31	0.04
08/07/	1.46	0.19	0.11	137.48	0.38	0.17
09/07/	0.81	0.18	0.11	135.93	0.48	0.07
10/07/	0.56	0.19	0.11	135.74	0.48	0.05
11/07/	0.77	0.20	0.11	134.63	0.40	0.04
12/07/	0.44	0.21	0.10	134.95	0.42	0.05
13/07/	0.97	0.25	0.10	136.78	0.40	0.08
14/07/	1.76	0.20	0.10	137.24	0.41	0.06
15/07/	0.62	0.19	0.10	137.23	0.41	0.05
16/07/	1.33	0.17	0.10	137.40	0.37	0.07
17/07/	0.66	0.20	0.10	134.31	0.48	0.08
18/07/	0.53	0.18	0.10	133.57	0.38	0.03
19/07/	0.30	0.17	0.10	135.14	0.39	0.01
20/07/	0.62	0.39	0.10	136.24	0.43	0.06
21/07/	0.51	0.18	0.10	137.20	0.36	0.03
22/07/	2.30	0.17	0.10	136.91	0.41	0.03
23/07/	2.67	0.19	0.10	135.81	0.41	0.02
24/07/	0.72	0.20	0.10	135.84	0.39	0.04
25/07/	0.76	0.20	0.10	136.05	0.41	0.04
26/07/	0.33	0.19	0.10	134.09	0.47	0.04
27/07/	1.03	0.17	0.10	134.93	0.49	0.05
28/07/	1.01	0.17	0.10	137.71	0.41	0.02
29/07/	1.18	0.18	0.10	136.35	0.40	0.02
30/07/	2.29	0.18	0.11	138.54	0.50	0.06
min	0.30	0.17	0.10	133.57	0.31	0.01
max	4.41	0.39	0.11	139.07	0.50	0.17
MMV	1.41	0.19	0.10	136.34	0.42	0.05

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown