



Menesine ataskaita: 08/2026

	UAB GREN Klaipėda			sugeneruota: 8/23/2026		
	Klaip L1 H ₂ O	Klaip L1 CO ₂	Klaip L1 CO	Klaip L1 SO ₂	Klaip L1 NH ₃	Klaip L1 HCl
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/08/	18.50	7.91	3.22	0.96	1.39	0.14
02/08/	18.15	7.85	3.79	1.19	1.37	0.13
03/08/	17.49	7.91	1.90	1.01	1.36	0.12
04/08/	16.60	7.91	3.03	1.32	1.33	0.13
05/08/	17.02	7.89	3.60	2.35	1.35	0.13
06/08/	17.65	7.93	3.29	3.29	1.37	0.16
07/08/	17.07	7.90	4.02	2.20	1.33	0.14
08/08/	17.12	7.94	1.90	0.80	1.34	0.13
09/08/	18.82	7.87	3.09	0.99	1.37	0.13
10/08/	17.26	7.84	2.23	0.85	1.38	0.12
11/08/	16.77	7.91	5.98	0.25	1.41	0.12
12/08/	16.99	7.90	3.93	0.09	1.45	0.15
13/08/	17.25	7.93	3.83	0.07	1.44	0.13
14/08/	16.90	8.02	4.44	0.21	1.44	0.12
15/08/	18.40	7.91	3.23	0.07	1.47	0.13
16/08/	18.71	7.83	3.53	0.15	1.53	0.13
17/08/	18.29	7.81	3.39	0.12	1.52	0.12
18/08/	16.63	7.92	4.19	0.09	1.54	0.12
19/08/	16.45	7.88	6.39	0.23	1.50	0.14
20/08/	16.48	7.79	5.28	0.10	1.47	0.13
min	16.45	7.79	1.90	0.07	1.33	0.12
max	18.82	8.02	6.39	3.29	1.54	0.16
MMV	17.43	7.89	3.71	0.82	1.42	0.13

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 08/2026

	UAB Gren Klaipeda			sugenerouta: 8/23/2026		
	Klaip L1 HF	Klaip L1 CH ₄	Klaip L1 NO _x	Klaip L1 TOC	Klaip L1 Dulkes	Klaip L1 Srautas
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Flow
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/08/	0.08	0.00	133.20	0.35	0.05	226265.80
02/08/	0.08	0.00	133.18	0.31	0.03	224396.65
03/08/	0.08	0.00	133.66	0.38	0.03	225398.70
04/08/	0.08	0.00	133.47	0.33	0.06	224046.82
05/08/	0.08	0.00	133.35	0.31	0.05	223721.22
06/08/	0.08	0.00	132.84	0.36	0.02	224537.21
07/08/	0.08	0.00	133.13	0.33	0.02	224329.17
08/08/	0.08	0.00	133.19	0.32	0.01	224235.05
09/08/	0.08	0.00	134.07	0.34	0.02	229510.20
10/08/	0.08	0.00	133.24	0.34	0.03	225881.31
11/08/	0.08	0.00	132.56	0.27	0.04	223339.51
12/08/	0.08	0.00	133.77	0.27	0.04	224530.55
13/08/	0.08	0.01	133.64	0.36	0.02	224352.05
14/08/	0.07	0.00	133.36	0.36	0.03	224103.29
15/08/	0.08	0.00	134.15	0.44	0.03	227302.37
16/08/	0.08	0.00	133.72	0.41	0.03	226681.77
17/08/	0.08	0.00	133.93	0.42	0.02	226865.59
18/08/	0.07	0.00	132.92	0.39	0.05	223453.16
19/08/	0.07	0.00	133.21	0.29	0.02	222685.51
20/08/	0.07	0.00	133.38	0.26	0.02	222516.25
min	0.07	0.00	132.56	0.26	0.01	222516.25
max	0.08	0.01	134.15	0.44	0.06	229510.20
MMV	0.08	0.00	133.40	0.34	0.03	224907.61

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Mensina ataskaita: 08/2026

	UAB Gren Klaipeda				sugenerouta: 8/23/2026	
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
	°C	mbar	Vol%	mbar	°C	mg/Nm ³
Diena	°C	mbar	Vol%	mbar	°C	mg/Nm ³
01/08/	56.08	1035.07	5.53	1012.60	1085.05	3.59
02/08/	55.81	1040.17	5.61	1016.79	1046.44	4.18
03/08/	55.06	1043.15	5.79	1019.10	1057.51	2.11
04/08/	53.91	1038.73	5.86	1015.20	1037.78	3.38
05/08/	54.38	1036.10	5.74	1011.23	1033.49	4.01
06/08/	55.16	1035.13	5.63	1011.64	1062.39	3.66
07/08/	54.44	1035.76	5.73	1013.47	1032.37	4.43
08/08/	54.56	1040.59	5.70	1017.33	1054.03	2.11
09/08/	56.60	1043.33	5.57	1018.81	1026.70	3.43
10/08/	54.64	1033.54	5.78	1010.43	1023.26	2.48
11/08/	54.05	1035.31	5.63	1012.35	1051.68	6.66
12/08/	54.48	1046.85	5.61	1023.15	1060.20	4.38
13/08/	54.86	1049.98	5.59	1026.51	1080.62	4.27
14/08/	54.31	1044.89	5.53	1020.78	1064.55	4.93
15/08/	56.04	1038.04	5.49	1012.94	1071.99	3.59
16/08/	56.32	1029.80	5.41	1007.72	1068.64	3.94
17/08/	55.80	1029.00	5.47	1005.81	1053.11	3.77
18/08/	53.72	1024.20	5.53	1001.46	1066.48	4.66
19/08/	53.52	1025.32	5.42	1001.52	1040.83	7.10
20/08/	53.54	1024.27	5.45	1000.95	1065.65	5.89
min	53.52	1024.20	5.41	1000.95	1023.26	2.11
max	56.60	1049.98	5.86	1026.51	1085.05	7.10
MMV	54.86	1036.46	5.60	1012.99	1054.14	4.13

- = out of operation = < 2/3
M = Maintenance
G = > LV

X = no daily classing
F = Fault
R = Replacement

N = No Data
A = Startup / shutdown

D = > DLV



- = out of operation = < 2/3	X = no daily classing	N = No Data
M = Maintenance	F = Fault	A = Startup / shutdown
G = > LV D = > DLV	R = Replacement	