

Menesine ataskaita: 01.2023



	UAB Gren Klaipeda						sugeneruota: 1.02.2023
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	10.330	7.604	4.302	0.004	0.141	0.012	
2.01	8.252	7.680	5.219	0.000	0.156	0.017	
3.01	8.989	7.665	4.823	0.000	0.174	0.020	
4.01	8.951	7.701	5.272	0.000	0.156	0.012	
5.01	9.666	7.668	5.596	0.000	0.212	0.014	
6.01	12.227	7.707	5.052	0.381	0.282	0.032	
7.01	12.062	7.657	4.596	0.000	0.427	0.025	
8.01	9.915	7.664	4.376	0.000	0.328	0.010	
9.01	9.367	7.689	5.391	0.000	0.291	0.008	
10.01	8.932	7.693	4.980	0.006	0.254	0.014	
11.01	8.547	7.725	4.388	0.004	0.229	0.004	
12.01	8.596	7.695	3.603	0.004	0.221	0.020	
13.01	8.320	7.659	6.212	0.002	0.192	0.022	
14.01	9.048	7.640	4.983	0.002	0.256	0.025	
15.01	8.242	7.664	3.064	0.002	0.238	0.004	
16.01	8.526	7.668	3.299	0.002	0.211	0.002	
17.01	8.993	7.575	4.483	0.059	0.219	0.000	
18.01	9.174	7.648	4.495	0.002	0.255	0.000	
19.01	9.068	7.672	3.559	0.001	0.315	0.001	
20.01	9.631	7.720	3.501	0.000	0.374	0.003	
21.01	9.708	7.691	2.507	0.000	0.378	0.009	
22.01	9.494	7.667	1.514	0.000	0.480	0.008	
23.01	9.645	7.683	2.372	0.000	0.310	0.002	
24.01	9.489	7.718	3.631	0.000	0.299	0.005	
25.01	8.400	7.717	6.505	0.004	0.272	0.007	
26.01	8.837	7.694	4.502	0.005	0.357	0.003	
27.01	9.092	7.673	4.691	0.004	0.356	0.003	
28.01	9.381	7.670	3.450	0.005	0.372	0.012	
29.01	8.426	7.710	3.756	0.002	0.297	0.004	
30.01	8.637	7.660	3.899	0.093	0.249	0.001	
31.01	8.569	7.725	3.440	0.194	0.207	0.001	
min	8.242	7.575	1.514	0.000	0.141	0.000	
max	12.227	7.725	6.505	0.381	0.480	0.032	
MMV	9.242	7.678	4.241	0.025	0.274	0.010	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 01.2023



	UAB Gren Klaipeda						sugeneruota: 1.02.2023
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.01	0.029	0.001	143.768	0.000	0.165	223818.57	
2.01	0.021	0.000	143.422	0.000	0.153	221004.95	
3.01	0.020	0.000	143.751	0.000	0.146	226319.92	
4.01	0.019	0.000	143.441	0.000	0.156	228899.82	
5.01	0.020	0.000	144.346	0.000	0.204	228719.25	
6.01	0.020	0.000	143.156	0.000	X	231582.26	
7.01	0.020	0.000	143.909	0.000	X	229527.75	
8.01	0.019	0.000	143.560	0.000	0.216	233464.23	
9.01	0.019	0.000	143.534	0.000	0.146	229163.37	
10.01	0.019	0.000	143.645	0.000	0.116	226481.67	
11.01	0.019	0.000	143.597	0.000	0.158	227532.51	
12.01	0.021	0.000	143.583	0.000	0.131	227168.89	
13.01	0.022	0.000	143.892	0.000	0.125	223200.98	
14.01	0.022	0.024	143.715	0.012	0.141	225184.51	
15.01	0.020	0.000	143.693	0.000	0.129	225463.68	
16.01	0.020	0.000	143.734	0.000	0.151	226893.95	
17.01	0.019	0.000	143.830	0.000	0.152	231391.95	
18.01	0.020	0.000	143.581	0.000	0.194	230067.26	
19.01	0.020	0.000	144.001	0.000	0.138	229204.73	
20.01	0.020	0.000	144.332	0.000	0.156	232738.37	
21.01	0.020	0.000	143.846	0.000	0.154	233757.81	
22.01	0.020	0.000	143.720	0.000	0.144	232355.18	
23.01	0.020	0.000	143.462	0.000	0.166	231643.43	
24.01	0.020	0.000	143.581	0.000	0.143	230089.37	
25.01	0.021	0.000	143.611	0.000	0.157	226106.14	
26.01	0.020	0.000	143.643	0.000	0.146	226874.00	
27.01	0.020	0.000	143.878	0.000	0.129	229333.64	
28.01	0.019	0.000	144.109	0.000	0.220	230626.17	
29.01	0.021	0.000	143.570	0.000	0.142	224492.42	
30.01	0.021	0.000	143.513	0.000	0.146	223980.95	
31.01	0.020	0.000	144.536	0.000	0.759	225183.23	
min	0.019	0.000	143.156	0.000	0.116	221004.95	
max	0.029	0.024	144.536	0.012	0.759	233757.81	
MMV	0.020	0.001	143.741	0.000	0.262	228137.37	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							

Menesine ataskaita: 01.2023



	UAB Gren Klaipeda			sugeneruota: 1.02.2023		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.01	46.426	1024.084	6.678	1004.989	1043.759	4.792
2.01	42.736	1030.240	6.519	1011.532	1021.714	5.808
3.01	44.236	1031.025	6.401	1013.776	1025.542	5.351
4.01	44.254	1030.155	6.345	1013.226	1025.555	5.862
5.01	45.417	1016.105	6.480	999.896	1008.701	6.246
6.01	50.188	1032.897	6.198	1020.172	1012.888	5.611
7.01	49.902	1032.256	6.109	1017.483	1009.666	5.110
8.01	46.028	1029.410	6.342	1011.373	1019.518	4.862
9.01	44.914	1021.222	6.290	1003.345	1038.181	6.001
10.01	44.163	1029.282	6.329	1009.756	1027.276	5.540
11.01	43.355	1030.718	6.328	1012.483	1039.904	4.868
12.01	43.392	1024.046	6.401	1005.408	1025.573	4.006
13.01	42.761	1020.601	6.505	1001.648	1042.500	6.888
14.01	44.130	1023.956	6.449	1005.731	1029.420	5.506
15.01	42.511	1013.368	6.537	995.700	1037.949	3.410
16.01	43.135	1013.441	6.309	995.668	1041.124	3.664
17.01	44.051	1006.093	6.294	988.908	1043.850	4.989
18.01	44.488	1009.903	6.413	993.187	1006.408	4.992
19.01	44.397	1020.787	6.673	1002.630	1022.969	3.964
20.01	45.658	1030.583	6.583	1014.371	1022.918	3.898
21.01	45.866	1042.471	6.529	1025.693	1023.617	2.786
22.01	45.571	1049.703	6.485	1032.628	1023.983	1.691
23.01	45.968	1055.012	6.327	1037.901	1018.627	2.645
24.01	45.524	1055.180	6.453	1036.093	1018.297	4.060
25.01	43.208	1046.084	6.713	1026.913	1021.617	7.230
26.01	44.052	1036.682	6.626	1018.614	1039.708	4.990
27.01	44.636	1039.932	6.684	1022.424	1049.105	5.207
28.01	45.232	1040.170	6.314	1021.991	1056.874	3.838
29.01	43.058	1029.251	6.502	1010.181	1068.972	4.186
30.01	43.127	1009.452	6.458	991.055	1079.096	4.332
31.01	43.268	1015.836	6.736	997.641	1072.366	3.819
min	42.511	1006.093	6.109	988.908	1006.408	1.691
max	50.188	1055.180	6.736	1037.901	1079.096	7.230
MMV	44.698	1028.708	6.452	1011.047	1032.829	4.715
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2023



	UAB Gren Klaipeda						sugeneruota: 1.02.2023
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	0.005	0.019	0.048	179.710	0.000	0.236	
2.01	0.000	0.029	0.035	179.278	0.000	0.219	
3.01	0.000	0.034	0.034	179.688	0.000	0.208	
4.01	0.000	0.020	0.032	179.302	0.000	0.223	
5.01	0.000	0.024	0.034	180.433	0.000	0.291	
6.01	0.476	0.053	0.033	178.944	0.000	X	
7.01	0.000	0.042	0.033	179.886	0.000	X	
8.01	0.000	0.016	0.032	179.450	0.000	0.308	
9.01	0.000	0.013	0.032	179.418	0.000	0.208	
10.01	0.007	0.023	0.032	179.557	0.000	0.166	
11.01	0.005	0.007	0.032	179.497	0.000	0.226	
12.01	0.005	0.034	0.034	179.479	0.000	0.188	
13.01	0.002	0.036	0.037	179.865	0.000	0.179	
14.01	0.002	0.042	0.037	179.644	0.017	0.202	
15.01	0.002	0.006	0.034	179.617	0.000	0.184	
16.01	0.002	0.003	0.033	179.668	0.000	0.215	
17.01	0.074	0.001	0.032	179.788	0.000	0.217	
18.01	0.002	0.001	0.033	179.477	0.000	0.277	
19.01	0.001	0.002	0.033	180.002	0.000	0.197	
20.01	0.000	0.005	0.033	180.415	0.000	0.222	
21.01	0.001	0.015	0.033	179.808	0.000	0.220	
22.01	0.000	0.013	0.033	179.650	0.000	0.205	
23.01	0.000	0.004	0.033	179.327	0.000	0.237	
24.01	0.000	0.008	0.033	179.476	0.000	0.204	
25.01	0.005	0.011	0.034	179.514	0.000	0.225	
26.01	0.006	0.005	0.034	179.554	0.000	0.209	
27.01	0.004	0.004	0.033	179.847	0.000	0.184	
28.01	0.007	0.020	0.032	180.136	0.000	0.314	
29.01	0.003	0.006	0.035	179.462	0.000	0.203	
30.01	0.116	0.002	0.035	179.391	0.000	0.209	
31.01	0.242	0.001	0.034	180.670	0.000	1.085	
min	0.000	0.001	0.032	178.944	0.000	0.166	
max	0.476	0.053	0.048	180.670	0.017	1.085	
MMV	0.031	0.016	0.034	179.676	0.001	0.375	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							